



CERTIFICATE OF ANALYSIS

Client:	Denis Dolbec	Work Order Number:	300142
Company:	OCWA - SRF - Fauquier WTP	PO #:	18164
Address:	70 First Ave, Box 160	Regulation:	O.Reg. 170
	Smooth Rock Falls, ON, P0L 2B0	Project #:	Org. # 5312
Phone:	(705) 338-4677	Fax:	(705) 338-4586
Email:	ddolbec@ocwa.com	DWS #:	210000979
Sampled By:	Benoit Parent		

Date Order Received: 3/28/2017	Analysis Started: 3/28/2017
Arrival Temperature: 8.3°C	Analysis Completed: 3/30/2017

TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC	HPC
				Free	Combined			
F-1 Raw Water (Groundhog River) *	866432	Raw / Raw Water	3/27/2017 9:20 AM			<2*	50*	
F-1 Raw Water (Groundhog River) *	866432r	Raw / Raw Water	3/27/2017 9:20 AM			<2*	44*	
F-2 Treated Water	866433	Entry / Treated Water	3/27/2017 9:22 AM		2.4	0	0	<10
F-3 Town Hall	866434	Distribution / Treated Water	3/27/2017 10:50 AM		1.89	0	0	
F-4 Bleeder	866435	Distribution / Treated Water	3/27/2017 11:16 AM		0.87	0	0	10

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

* Sample required dilution, please refer to the accompanying spreadsheet for sample-specific method detection limits.

REPORT COMMENTS

Bacti Lot # n.a

This report has been approved by:

Brad Woodward, H.B.Sc.
Laboratory Director

LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count
 RESULTS ~ - No Data. Results Pending.
 INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)
 NDOGN - No Data, Overgrown with Non-Target
 NDOGT - No Data, Overgrown with Target
 NDOGHPC - No Data, Overgrown with HPC
 An 'r' after the Lab ID indicates a laboratory replicate.
 Results relate only to the items tested.